



Government of Bermuda

Ministry of **Public Works and Environment**

Department of **Public Lands and Building**

Addendum

For

Painting and Facade Lighting of Gibb's Hill Lighthouse.

Design-Build, Operations, and Training Contract

Procurement No.: **0199-TD/10/25**

Issued: Friday, November 07, 2025

Submission Deadline: Thursday, November 27, 2025: 03:00:00 PM local time

Addendum No, **2**

Addendum Type: Supplemental Information

The following addendum supersedes information contained in the solicitation document issued for this procurement to the extent referenced. This Addendum forms part of the solicitation documents and will be subject to all of the conditions set out in the contract conditions.

QUESTION AND RESPONSE TO QUESTION WITH SUPPLEMENTAL INFORMATION

Question 1:	What surface coating has the Government used in the past and found to be appropriate for the conditions?
Answer 1:	Exterior: Undercoat RUS-KIL Primer Red; Top Coats (2) Sea Guard White Interior: Undercoat RUS-KIL Primer Red, Top Coats (2) semi gloss marine quality enamel coating. Supplier: Bermuda Paint 9 Watlington Road Devonshire 236-4662 Alternate exterior product or approved equal: Moisture Cure Urethane Approved Coating System Spot Prime MC Universal 100 Tie Coat MC Universal 100 Topcoat MC Luster 100 Reducer MC-Thinner or MC-Thinner 100 Accelerator PURQuik® Supplier: Wasser Technologies Ph: 800-627-2968 Fx: 253-850-3098 E-mail: bforde@wassercoatings.com

End of Addenda No:2